

Resolution A.952(23)

*Adopted on 5 December 2003
(Agenda item 17)*

GRAPHICAL SYMBOLS FOR SHIPBOARD FIRE CONTROL PLANS

THE ASSEMBLY,

RECALLING Article 15(i) of the Convention on the International Maritime Organization concerning the functions of the Assembly in relation to regulations and guidelines concerning maritime safety,

BEARING IN MIND that regulation II-2/15.2.4 of the International Convention for the Safety of Life at Sea (SOLAS), 1974, as amended, requires that fire control plans be permanently exhibited for the guidance of the ship's officers and that a duplicate set of fire control plans or a booklet containing such plans be permanently stored in a prominently marked weathertight enclosure outside the deckhouse for the assistance of shore-side fire-fighting personnel,

RECOGNIZING that the use of international symbols for shipboard fire control plans would greatly increase their usefulness, both for the crew of the ship and for shore-based fire brigades,

RECALLING ALSO resolution A.654(16) on Graphical symbols for fire control plans,

NOTING that ISO had, in close co-operation with IMO, developed standard ISO 17631:2002 – Ships and marine technology – Shipboard plans for fire protection, life-saving appliances and means of escape, providing fire protection symbols which generally conform to the corresponding symbols set out in resolution A.654(16),

NOTING IN PARTICULAR that, through MSC/Circ.1050, Member Governments had been invited to bring standard ISO 17631:2002 to the attention of shipbuilders, shipowners, shipoperators, shipmasters, shore-based fire-fighting personnel and other parties concerned with the preparation or use of shipboard fire control plans, so that they might use it, on a voluntary basis, for the preparation or use of the shipboard fire control plans required by SOLAS regulation II-2/15.2.4, pending the outcome of the work related to the revision of resolution A.654(16),



HAVING CONSIDERED the recommendation made by the Maritime Safety Committee at its seventy-seventh session,

1. ADOPTS the Graphical symbols for shipboard fire control plans, set out in the annex to the present resolution;
2. URGES Governments to bring the aforementioned graphical symbols to the attention of shipbuilders, shipowners, shipoperators, shipmasters, shore-based fire-fighting personnel and other parties concerned with the preparation or use of shipboard fire control plans with a view to encouraging their use for the preparation of the shipboard fire control plans required by SOLAS regulation II-2/15.2.4, for ships constructed on or after 1 January 2004;
3. INVITES Governments to bring standard ISO 17631:2002 to the attention of shipbuilders, shipowners, shipoperators and shipmasters so that they may use the additional guidance contained therein for the preparation of shipboard fire control plans;
4. AGREES that ships constructed before 1 January 2004 may continue to carry fire control plans that use the graphical symbols contained in resolution A.654(16);
5. REQUESTS the Maritime Safety Committee to keep this resolution under review and to amend it as necessary.






Annex

GRAPHICAL SYMBOLS FOR SHIPBOARD FIRE CONTROL PLANS*

Graphical symbols for structural fire protection




No.	Graphical symbol	Reference	Comments on use
1.1		A-class division	
1.2		B-class division	
1.3		Main vertical zone	
1.4		A-class hinged fire door	The symbol should be at the door position and should show the actual direction of the door. Add WT to the right side of the symbol in the case of a watertight door. Add SWT to the right side of the symbol in the case of a semi-watertight door.
1.5		B-class hinged fire door	The symbol should be at the door position and should show the actual direction of the door. Add WT to the right side of the symbol in the case of a watertight door. Add SWT to the right side of the symbol in the case of a semi-watertight door.
1.6		A-class hinged self-closing fire door	The symbol should be at the door position and should show the actual direction of the door. Add WT to the right side of the symbol in the case of a watertight door. Add SWT to the right side of the symbol in the case of a semi-watertight door.
1.7		B-class hinged self-closing fire door	The symbol should be at the door position and should show the actual direction of the door. Add WT to the right side of the symbol in the case of a watertight door. Add SWT to the right side of the symbol in the case of a semi-watertight door.







* A legend of symbols and explanations should be a constituent part of any fire control plan and contain a list of the graphical symbols used in the plan, together with the appropriate explanations, and may include additional special information such as the type of extinguishing media used in fixed fire-extinguishing systems.

No.	Graphical symbol	Reference	Comments on use
1.8		A-class sliding fire door	The symbol should be at the door position and should show the actual direction of the door. Add WT to the right side of the symbol in the case of a watertight door. Add SWT to the right side of the symbol in the case of a semi-watertight door.
1.9		B-class sliding fire door	The symbol should be at the door position and should show the actual direction of the door. Add WT to the right side of the symbol in the case of a watertight door. Add SWT to the right side of the symbol in the case of a semi-watertight door.
1.10		A-class self-closing sliding fire door	The symbol should be at the door position and should show the actual direction of the door. Add WT to the right side of the symbol in the case of a watertight door. Add SWT to the right side of the symbol in the case of a semi-watertight door.
1.11		B-class self-closing sliding fire door	The symbol should be at the door position and should show the actual direction of the door. Add WT to the right side of the symbol in the case of a watertight door. Add SWT to the right side of the symbol in the case of a semi-watertight door.
1.12		Ventilation remote control or shut-off	Colour of the circle and a letter at the right side of the symbol should indicate as follows: A = blue for accommodation and service spaces; M = green for machinery spaces; C = yellow for cargo spaces.
1.13		Remote control for skylight	
1.14		Remote control for watertight doors or fire doors	Add WT to the right side of the symbol to indicate remote control for watertight doors or FD to indicate remote control for fire doors.
1.15		Fire damper	Colour of the circle and a letter at the right side of the symbol should indicate as follows: A = blue for accommodation and service spaces; M = green for machinery spaces; C = yellow for cargo spaces. Identification number of the damper may be shown at the bottom of the symbol.






No.	Graphical symbol	Reference	Comments on use
1.16		Closing device for ventilation inlet or outlet	Colour of the circle and a letter at the right side of the symbol should indicate as follows: A = blue for accommodation and service spaces; M = green for machinery spaces; C = yellow for cargo spaces. Identification number of the closing device may be shown at the bottom of the symbol.
1.17		Remote control for fire damper(s)	Colour of the circle and a letter at the right side of the symbol should indicate as follows: A = blue for accommodation and service spaces; M = green for machinery spaces; C = yellow for cargo spaces. Identification number of the damper may be shown.
1.18		Remote control for closing device(s) for ventilation inlet and outlet	Colour of the circle and a letter at the right side of the symbol should indicate as follows: A = blue for accommodation and service spaces; M = green for machinery spaces; C = yellow for cargo spaces. Identification number of the closing device(s) may be shown.








Graphical symbols for fire-protection appliances



No.	Graphical symbol	Reference	Comments on use
2.1		Fire protection appliances or structural fire protection plan	
2.2		Remote control for fire pump(s)	
2.3		Fire pump(s)	The type, quantity of water delivered per time unit, and pressure head should be indicated either at the right side of the symbol or in the legend.
2.4		Remote control for emergency fire pump or fire pump supplied by the emergency source of power	
2.5		Emergency fire pump	The type, quantity of water delivered per time unit, and pressure head should be indicated either at the right side of the symbol or in the legend.

No.	Graphical symbol	Reference	Comments on use
2.6		Fuel pump(s) remote shut-off	
2.7		Lube oil pump(s) remote shut-off	
2.8		Remote control for bilge pump(s)	
2.9		Remote control for emergency bilge pump	
2.10		Remote control for fuel oil valves	
2.11		Remote control for lube oil valves	
2.12		Remote control for fire pump valve(s)	
2.13		Remote release station	Indicate at the bottom of the symbol the protected space. Extinguishing media should be colour coded in the lower part of the symbol and be indicated by a letter at the right side of the symbol as follows: grey – CO₂ for carbon dioxide or N for nitrogen, brown – H for gas other than CO ₂ or N (type of gas to be indicated), white – P for powder, green – W for water.
2.14		International shore connection	

No.	Graphical symbol	Reference	Comments on use
2.15		Fire hydrant	
2.16		Fire main section valve	Indicate the reference number of the valve at the right side of the symbol.
2.17		Sprinkler section valve	Indicate the reference number of the valve at the right side of the symbol. This symbol may also be applied to equivalent water extinguishing systems. Valves for automatic dry-pipe sprinkler systems should be indicated in the legend.
2.18		Powder section valve	Indicate the reference number of the valve at the right side of the symbol.
2.19		Foam section valve	Indicate the reference number of the valve at the right side of the symbol.
2.20		Fixed fire-extinguishing installation	Extinguishing media should be colour-coded in the centre part of the symbol and indicated by a letter on top of the symbol as follows: grey – CO₂ for carbon dioxide or N for nitrogen, yellow – F for foam, brown – H for gas other than CO ₂ or N (type of gas to be indicated), white – P for powder, green – W for water.
2.21		Fixed fire-extinguishing battery	Extinguishing media should be colour-coded in the lower part of the symbol and indicated by a letter on top of the symbol as follows: grey – CO₂ for carbon dioxide or N for nitrogen, yellow – F for foam, brown – H for gas other than CO ₂ or N (type of gas to be indicated), white – P for powder, green – W for water.
2.22		Fixed fire-extinguishing bottle, placed in protected area	Extinguishing media should be colour-coded in the centre part of the symbol and indicated by a letter on top of the symbol as follows: grey – CO₂ for carbon dioxide or N for nitrogen, yellow – F for foam, brown – H for gas other than CO ₂ or N (type of gas to be indicated), white – P for powder, green – W for water.
2.23		High-expansion foam supply trunk (outlet)	Indicate at the bottom of the symbol the protected space, if necessary.

No.	Graphical symbol	Reference	Comments on use
2.24		Water spray system valves	Indicate at the bottom of the symbol the protected space, if necessary.
2.25		Inert gas installation	
2.26		Monitor	Extinguishing media should be colour-coded in the centre part of the symbol and indicated by a letter on the right side of the symbol as follows: yellow – F for foam, white – P for powder, green – W for water.
2.27		Fire hose and nozzle	Indicate the hose length at the right side of the symbol; where only one type of hose is used, the information can be shown in the legend. Extinguishing media should be colour-coded in the lower part of the symbol and indicated by a letter on the right side of the symbol as follows: yellow – F for foam, white – P for powder, green – W for water.
2.28		Fire extinguisher	Indicate type of extinguishing media (CO₂ for carbon dioxide, F for foam, H for gas other than CO ₂ (type of gas to be indicated), P for powder, W for water) and capacity (kg for gas and powder, litres for water and foam) at the right side of the symbol. Media should be colour-coded in the lower part of the symbol as follows: grey for carbon dioxide, yellow for foam, brown for gas other than CO ₂ , white for powder, green for water.
2.29		Wheeled fire extinguisher	Indicate type of extinguishing media (CO₂ for carbon dioxide, F for foam, H for gas other than CO ₂ (type of gas to be indicated), P for powder, W for water) and capacity (kg for gas and powder, litres for water and foam) at the right side of the symbol. Media should be colour-coded in the centre part of the symbol as follows: grey for carbon dioxide, yellow for foam, brown for gas other than CO ₂ , white for powder, green for water.
2.30		Portable foam applicator unit or relevant spare tank(s)	
2.31		Fire locker	Indicate the number of the fire locker at the right side of the symbol. The principal contents of each fire locker should be indicated in the legend.

No.	Graphical symbol	Reference	Comments on use
2.32		Space or group of spaces protected by fire-extinguishing system	Indicate type of extinguishing media (CO₂ for carbon dioxide, F for foam, H for gas other than CO ₂ (type of gas to be indicated), P for powder, W for water, S for sprinkler or high-pressure water extinguishing system) and capacity (kg for gas and powder, litres for water and foam) at the top of the symbol. Add suffix "L" for fixed local application fire-fighting system. Media should be colour-coded in the symbol as follows: grey for carbon dioxide, yellow for foam, brown for gas other than CO ₂ , white for powder, green for water, orange for sprinkler or high-pressure water extinguishing system.
2.33		Water fog applicator	
2.34		Emergency source of electrical power (generator)	
2.35		Emergency source of electrical power (battery)	
2.36		Emergency switchboard	
2.37		Air compressor for breathing devices	
2.38		Control panel for fire detection and alarm system	
2.39		Push button/switch for general alarm	
2.40		Manually operated call point	The use of this symbol is optional at the discretion of the competent authority.

No.	Graphical symbol	Reference	Comments on use
2.41		Space or group of spaces monitored by smoke detector(s)	The space(s) should be identified.
2.42		Space or group of spaces monitored by heat detector(s)	The space(s) should be identified.
2.43		Space or group of spaces monitored by flame detector(s)	The space(s) should be identified.
2.44		Space monitored by gas detector(s)	

Graphical symbols for means of escape and escape-related devices

No.	Graphical symbol	Reference	Comments on use
3.1		Primary escape route	
3.2		Secondary escape route	
3.3		Emergency escape breathing device (EEBD)	Indicate the quantity of the EEBDs stowed at the right side of the symbol.